

GENERAL NOTES

1. ALL FIRE HYDRANTS AND VALVE BOXES TO BE SET TO PROPOSED FINAL GRADE WITH STEAMER NOZZLE 24" ABOVE GROUND LEVEL.
2. ALL EXISTING WATER MAINS BEING ABANDONED BY ANY PROJECT ARE TO REMAIN THE PROPERTY OF THE CITY OF EDMOND, AND SHALL BE SALVAGED FOR THE CITY WATER DEPARTMENT.
3. SANITARY SEWER CROSSINGS TO BE DUCTILE IRON PIPE 10' EITHER SIDE OF WATER MAIN, TO BE MEASURED AT RIGHT ANGLES, IN ACCORDANCE WITH EDMOND CITY WATER DEPARTMENT STANDARD AND/OR OKLAHOMA STATE DEPARTMENT OF ENVIROMENTAL QUALITY STANDARDS.
4. SET END OF MAIN STUBS IN CUL-DE-SACS AT A POINT 5'-0" OFF FRONT PROPERTY LINE. THIS POINT BEING IN LINE WITH SIDE PROPERTY LINE.
5. IN INSTANCES WHERE FLOW LINES ARE NOT INDICATED ON THE DRAWINGS, MAIN SHALL BE CONSTRUCTED WITH A MINIMUM OF 4'-0" COVER, OR AS DIRECTED BY THE CITY ENGINEER AND IN ACCORDANCE WITH OKLAHOMA STATE DEPARTMENT OF ENVIRONMENTAL QUALITY STANDARDS.
6. FIRE HYDRANTS SHALL BE LOCATED 5' TO 9' FROM BACK OF CURB. SIDEWALK LOCATIONS TO BE PRE-DETERMINED SO HYDRANTS WILL NOT BE LOCATED IN SIDEWALK.
7. ALL EMBANKMENTS AND BACKFILL SHALL MEET CITY OF EDMOND STANDARD SPECIFICATION 615.03 (g).

D:\CITY WATER ENGINEERING\CONSTRUCTION DRAWINGS\EDMOND\STANDARD CONSTRUCTION DRAWINGS (JULY 2004)\WATER & SEWER\WL-01-01.DWG
 JULY 26, 2004 REBER

	◇	7/26/2004	HYDRANT
REVISIONS	NO.	DATE	ITEM CHANGED
CITY OF EDMOND			GENERAL NOTES
ENGINEERING DEPARTMENT			
CONSTRUCTION STANDARDS			
			WATER
			SPECIFICATION NO. 615
			WL-01 PAGE 1